



INVITATION FOR BID

**Arlington Public Schools
Purchasing Office**

August 31, 2016

ADDENDUM NO. 1

IFQ #: #11FY17

TITLE: GENERATOR PREVENTIVE MAINTENANCE AND REPAIR

DUE DATE: Thursday, September 8, 2016, prior to 1:00 PM, Local Prevailing Time

THE SUBJECT INVITATION FOR BID IS AMENDED AS FOLLOWS:

Bidder Questions and APS Responses:

Question 1: Section 3.2.1.2 – States that the batteries are to be replaced every three (3) years, with the new batteries and disposal of the old batteries being handled by APS. Are we to assume that the batteries for all the units will need to be replaced within this first year?

Answer 1: No. Batteries will be replaced as needed or three (3) years after the installation date. APS does not have records to show when the batteries were originally installed.

Question 2: Is the request to change the batteries every three (3) years going to fall under Section 3.4 – Scheduled/Unscheduled Non-Critical Repairs?

Answer 2: No. Batteries will be replaced during the Quarterly Preventive Maintenance Inspection that falls three (3) years after the installation date. Your pricing for the Preventive Maintenance Inspections should take this into account.

This Addendum #1 for RFP 11FY17 – GENERATOR PREVENTIVE MAINTENANCE AND REPAIR and must be signed, dated and received in the Purchasing Office prior to the date and time stated above “OR” acknowledgement of receipt of this addendum may be noted on Page 13 of the Invitation For Bid.

NAME OF OFFEROR: _____

Address: _____

SIGNATURE: _____ **DATE:** _____

Kenneth R. Lawson

Kenneth R. Lawson, CPPB, VCO
Buyer/Purchasing Department
1426 North Quincy Street
Arlington VA. 22207
(703) 228-6193
ken.lawson@apsva.us

