

# ARLINGTON PUBLIC SCHOOLS - SYSTEM WIDE TESTING OF LEAD IN WATER (May-June 2016)

Elementary	Draw Kitchen 1	Flush 2	Draw Fountain 1	Flush 2	Draw Other 1	Flush 2	Middle	Flush Kitchen 1	Draw 2	Flush Fountain 1	Draw 2	Flush Other 1	2
Abingdon Elementary School	ND	ND	ND	ND	ND	ND	Gunston Middle School	ND	ND	ND	ND	1.4	ND
Arlington Traditional School	ND	ND	ND	ND	ND	ND	Jefferson Middle School	ND	ND	ND	ND	ND	ND
Ashlawn Elementary School	ND	ND	ND	ND	ND	ND	Kenmore Middle School	ND	ND	ND	ND	ND	ND
Barcroft Elementary School	ND	ND	ND	ND	ND	ND	Swanson Middle School	ND	ND	ND	ND	ND	ND
Barrett Elementary School	ND	ND	ND	ND	ND	ND	HB Woodlawn and Stratford	ND	ND	ND	ND	ND	ND
Campbell Elementary School	ND	ND	ND	ND	ND	ND	Williamsburg Middle School	1.4	ND	ND	ND	ND	ND
Carlin Springs Elementary School	1.6	ND	ND	ND	ND	ND							
Claremont Elementary School	ND	ND	ND	ND	ND	ND							
Discovery Elementary School	ND	ND	ND	ND	ND	ND							
Drew Model School	1.2	ND	ND	ND	ND	ND	<b>High</b>						
Glebe Elementary School	ND	ND	ND	ND	ND	ND	Career Center	ND	ND	2.1	1.6	2.9	ND
Henry Elementary School	ND	ND	ND	ND	ND	ND	Fenwick (New Arl. Com) *	4.1	ND	1.1	ND	2.3	ND
Hoffman-Boston Elementary School	ND	ND	ND	ND	ND	ND	Marshall New Directions-	ND	ND	ND	ND	ND	ND
Jamestown Elementary School	3.3	8.2	3.2	77	3.9	13	Langston High School	ND	ND	ND	ND	ND	ND
Key Elementary School	ND	ND	ND	ND	ND	ND	Washington Lee High School	ND	ND	ND	ND	ND	ND
Long Branch Elementary School	ND	ND	ND	ND	ND	ND	Wakefield High School	ND	ND	ND	ND	ND	ND
McKinley Elementary School	ND	ND	ND	ND	3.3	1	Yorktown High School	ND	ND	ND	ND	ND	ND
Nottingham Elementary School	ND	ND	ND	ND	1.5	ND							
Oakridge Elementary School	ND	ND	ND	ND	ND	ND	<b>Other</b>						
Randolph Elementary School	ND	ND	ND	ND	ND	ND	Ed Center	ND	ND	1.5	1.8	ND	ND
Reed The Children's School	ND	ND	ND	ND	ND	ND	Planetarium *	1.8	1.5	1.5	2.9	1.5	1.7
Science Focus Elementary School	ND	ND	ND	ND	ND	2.1	Facilities	ND	ND	ND	ND	ND	ND
Taylor Elementary School	ND	ND	ND	ND	ND	ND							
Tuckahoe Elementary School	ND	ND	ND	ND	ND	ND							

\* No kitchen sink so tested additional faucet (s)

**NOTES:**

**TEST 1 DRAW** A 'draw' is taken immediately when an outlet is turned on  
**TEST 2 FLUSH** A 'flush' is taken after water has flowed for thirty seconds  
**'OTHER'** Is typically a random faucet elsewhere in the building

**ND** Equals "NONE DETECTED" - no lead detected  
**PPB** Equals Parts Per Billion detected (lead)  
**15.0 PPB +** Requires remedial action