

**SUMMER 2019 - RESULTS FOR TESTING OF LEAD IN WATER LEVELS AT ELEVEN APS SITES  
(THIRD BATCH IN THREE YEAR CYCLE SHOWN IN THIS 'MAINTENANCE' WEB SECTION)**

				In Parts/Billion- PPB	
Collect Date	Site/Location	Param	Method	Result	
5/24/2019	Wakefield - 3 Compartment Kitchen Sink	Lead	EPA 200.8	ND	
5/24/2019	Wakefield - Cafeteria Bottle Filler	Lead	EPA 200.8	ND	
5/24/2019	Wakefield - Clinic Sink	Lead	EPA 200.8	1.7	
5/24/2019	Kenmore - 3 Compartment Kitchen Sink	Lead	EPA 200.8	0.4	
5/24/2019	Kenmore - Cafeteria Fountain	Lead	EPA 200.8	ND	
5/24/2019	Kenmore - Clinic Sink	Lead	EPA 200.8	0.4	
5/24/2019	Career Center - Cullinary Sink	Lead	EPA 200.8	1.1	
5/24/2019	Career Center - Fountain By Clinic	Lead	EPA 200.8	ND	
5/24/2019	Career Center - Clinic Sink	Lead	EPA 200.8	1.2	
5/29/2019	Langston - 3 Compartment Kitchen Sink	Lead	EPA 200.8	0.6	
5/29/2019	Langston - Fountain By 115	Lead	EPA 200.8	ND	
5/29/2019	Langston - Fountain By 315	Lead	EPA 200.8	ND	
5/29/2019	Yorktown - Bottle Filler By Main office	Lead	EPA 200.8	ND	
5/29/2019	Yorktown - Clinic Bubbler	Lead	EPA 200.8	ND	
5/29/2019	Yorktown - 3 Compartment Kitchen Sink	Lead	EPA 200.8	3.5	
5/29/2019	Discovery - Clinic Sink	Lead	EPA 200.8	ND	
5/29/2019	Discovery - Cafeteria Bottle Filler	Lead	EPA 200.8	ND	
5/29/2019	Discovery - 3 Compartment Kitchen Sink	Lead	EPA 200.8	ND	
5/30/2019	Reed - 3 Compartment Kitchen Sink	Lead	EPA 200.8	0.7	
5/30/2019	Reed - Clinic Sink	Lead	EPA 200.8	0.2	
5/30/2019	Reed - Fountain By 1115	Lead	EPA 200.8	ND	
5/30/2019	Wash-Liberty - 3 Compartment Kitch. Sink	Lead	EPA 200.8	0.3	
5/30/2019	Wash-Liberty - Bottle Filler By 1600	Lead	EPA 200.8	ND	
5/30/2019	Wash-Liberty - Bottle Filler By 1008	Lead	EPA 200.8	ND	
5/30/2019	H.B. Woodlawn - Water Fountain By 105	Lead	EPA 200.8	ND	
5/30/2019	H.B. Woodlawn - Cafeteria Water Fountain	Lead	EPA 200.8	0.7	
5/30/2019	H.B. Woodlawn - 3 Compartment Kitch. Sink	Lead	EPA 200.8	0.7	
5/31/2019	ACHS Fenwick - Fountain By 105/106	Lead	EPA 200.8	ND	
5/31/2019	ACHS Fenwick - Fountain By 205	Lead	EPA 200.8	ND	
5/31/2019	ACHS Fenwick - Laboratory Sink 218	Lead	EPA 200.8	ND	
5/31/2019	Facilities - Lower Level Fountain	Lead	EPA 200.8	ND	
5/31/2019	Facilities - Main Level Bottle Filler	Lead	EPA 200.8	0.3	
5/31/2019	Facilities - Lunch Room Sink	Lead	EPA 200.8	ND	

**NB: Most are None Detected (ND) or miniscule traces. Actionable level is 15.00 PPB**

Any questions on these results can be directed to Jim Meikle, Director of maintenance APS - 703 228 6617