

SUMMER 2020 - RESULTS FOR TESTING OF LEAD IN WATER LEVELS AT 13 APS LOCATIONS
(FIRST BATCH IN ROTATING THREE YEAR CYCLE SHOWN IN THIS 'MAINTENANCE' WEB SECTION)

			In Parts/Billion - PPB	
Collect Date	Location	Param	EPA 200.8	Result
7/30/2020	Abingdon - Main Kitchen Sink	Lead	EPA 200.8	ND
7/30/2020	Abingdon - Bottle Filler by RM 124	Lead	EPA 200.8	ND
7/30/2020	Arl. Science Focus - Main Kitchen Sink	Lead	EPA 200.8	0.0003
7/30/2020	Arl. Science Focus - Bottle Filler by RM 124	Lead	EPA 200.8	0.0014
7/29/2020	Barcroft - Water Fountain by Girls RM - 1st Floor	Lead	EPA 200.8	0.0002
7/29/2020	Barcroft - Water Fountain by Gym	Lead	EPA 200.8	ND
7/29/2020	Barrett - Water Fountain by Girls RM - 1st Floor	Lead	EPA 200.8	0.0004
7/29/2020	Barrett - Water Fountain by Exit 5	Lead	EPA 200.8	ND
7/29/2020	Claremont - Water Fountain in MPR	Lead	EPA 200.8	ND
7/29/2020	Claremont - Water Fountain by RM 144	Lead	EPA 200.8	0.0007
7/29/2020	Drew - Lobby Rest Rooms	Lead	EPA 200.8	ND
7/29/2020	Drew - Water Fountain in MPR	Lead	EPA 200.8	0.0003
7/30/2020	Gunston - Main Kitchen Sink	Lead	EPA 200.8	0.0005
7/30/2020	Gunston - Bottle Filler by RM 101C	Lead	EPA 200.8	0.0002
7/29/2020	Hoffman Boston - Water Fountain by RM 124	Lead	EPA 200.8	0.0005
7/29/2020	Hoffman Boston - Water Fountain by Gym	Lead	EPA 200.8	0.0023
7/31/2020	Jamestown - Bottle Filler by MPR	Lead	EPA 200.8	ND
7/31/2020	Jamestown - Water Fountain by RM 602	Lead	EPA 200.8	ND
7/30/2020	Randolph - Main Kitchen Sink	Lead	EPA 200.8	0.0002
7/30/2020	Randolph - Bottle Filler by RM B107	Lead	EPA 200.8	ND
7/31/2020	Taylor - Bottl Filler by MPR	Lead	EPA 200.8	0.0005
7/31/2020	Taylor - Staff Room Water Fountain	Lead	EPA 200.8	ND
7/31/2020	Thos. Jefferson - Wat. Fountain between B/G Lobby Rest Rooms	Lead	EPA 200.8	ND
7/31/2020	Thos. Jefferson - Water Fountain by Main Office	Lead	EPA 200.8	0.0002
7/31/2020	Tuckahoe - Bubbler at RM 171	Lead	EPA 200.8	ND
7/31/2020	Tuckahoe - Bottle Filler by Phone Booth	Lead	EPA 200.8	ND
NB: Half are at None Detected (ND) the other half are all at miniscule traces. Actionable level is 15.00 PPB				
Any questions on these results can be directed to Jim Meikle, Director of Maintenance APS - 703 228 6617				