

Classroom Capacity Considerations Based on Social Distancing and Ventilation Guidelines

| | |
|--------------------|----------------------|
| Publication Date | 12/10/2020 |
| Updated time stamp | 12/14/202012/22/2020 |

| School Status per Level | | | | |
|---|---------|---------|---------|---------|
| | Level 1 | Level 2 | Level 3 | Level 4 |
| Elementary Schools | | | | |
| Claremont | | | | |
| Suitable for full capacity, in-person return when social distancing guidelines lifted, sufficient seats for level planned | | | | |
| Further work needed to improve capacity for some future planned phases and ultimately full in-person return | | | | |

| Potential Number of Students to Return per Level | | | | |
|--|-----------------|-----------|------------|----------------------------|
| | Level 1 | Level 2 | Level 2 | Level 1 & 2 |
| | Tues/Wed/Th/Fri | Tues /Wed | Thurs/Frid | Maximum per day |
| Student Count | 0 | 158 | 213 | 213 |
| | | | | 325 Hybrid School Capacity |

| | | Column C | Column D | Column E | Column F | |
|-------------|--------------|--|------------------------------------|--|---|------------------------|
| Room Number | Room Use | Classroom capacity based on social distancing requirements | Room capacity based on ASHRAE 62.1 | Room capacity with Certified Room Air Cleaners | Hybrid In-person classroom capacity (optimum capacity of columns C, D or E) | |
| 127 | GR-4 | 10 | Original Design Occupancy | | 10 | |
| 128 | VPI | 8 | Original Design Occupancy | | 8 | |
| 130 | VPI | 8 | Original Design Occupancy | | 8 | |
| 131 | Kindergarten | 6 | Original Design Occupancy | 6 | 6 | FCU |
| 133 | Kindergarten | 8 | Original Design Occupancy | 8 | 8 | FCU |
| 134 | Kindergarten | 8 | Original Design Occupancy | 8 | 8 | FCU |
| 135 | Kindergarten | 8 | Original Design Occupancy | 8 | 8 | FCU |
| 136 | Kindergarten | 8 | Original Design Occupancy | 8 | 8 | FCU |
| 138 | Kindergarten | 8 | Original Design Occupancy | 8 | 8 | FCU |
| 154 | GR-4 | 8 | Original Design Occupancy | | 8 | |
| 156 | GR-4 | 8 | Original Design Occupancy | | 8 | |
| 161 | GR-3 | 8 | Original Design Occupancy | | 8 | |
| 163 | GR-3 | 8 | Original Design Occupancy | | 8 | |
| 166 | GR-3 | 8 | Original Design Occupancy | | 8 | |
| 168 | GR-3 | 8 | Original Design Occupancy | | 8 | |
| 169 | GR-3 | 8 | Original Design Occupancy | | 8 | |
| 171 | GR-3 | 12 | Original Design Occupancy | | 12 | |
| 178 | GR-2 | 13 | Original Design Occupancy | 13 | 13 | FCU |
| 179 | GR-2 | 13 | Original Design Occupancy | 13 | 13 | FCU |
| 184 | GR-2 | 13 | Original Design Occupancy | 13 | 13 | FCU |
| 185 | GR-2 | 13 | Original Design Occupancy | 13 | 13 | FCU |
| L09 | GR-4 | 10 | Original Design Occupancy | | 10 | |
| L15 | GR-4 | 8 | Original Design Occupancy | | 8 | |
| L19 | GR-4 | 8 | Original Design Occupancy | | 8 | |
| L21 | GR-5 | 8 | Original Design Occupancy | | 8 | |
| L25 | GR-5 | 8 | Original Design Occupancy | 8 | 8 | FCU |
| L29 | GR-5 | 8 | Original Design Occupancy | 8 | 8 | FCU |
| L31 | GR-5 | 8 | Original Design Occupancy | 8 | 8 | FCU |
| L32 | GR-4 | 12 | Original Design Occupancy | 12 | 12 | FCU |
| Relo 501 | GR-1 | 9 | Original Design Occupancy | | 9 | |
| Relo 502 | GR-1 | 9 | Original Design Occupancy | | 9 | |
| Relo 503 | GR-1 | 9 | Original Design Occupancy | | 9 | |
| Relo 504 | GR-1 | 9 | Original Design Occupancy | | 9 | |
| Relo 505 | GR-1 | 9 | Original Design Occupancy | | 9 | |
| Relo 506 | N/A | 9 | Original Design Occupancy | | 9 | |
| Relo 507 | N/A | 9 | Original Design Occupancy | | 9 | |
| | | | | 14 | 325 | Hybrid School Capacity |

DISCLAIMER: Living document subject to revisions based on local public health guidance and updates from CDC and ASHRAE. Occupancy has been reduced by the ASHRAE 62.1 code due to the number of outside air exchanges.