

| | |
|--|--|
| SUMMER 2023 - RESULTS FOR TESTING OF LEAD IN WATER LEVELS AT 15 APS LOCATIONS | |
| (ROTATING THREE YEAR CYCLE SHOWN IN THIS 'MAINTENANCE' WEB SECTION) | |

| Collect Date | Location | Param | In Parts/Billion - PPB | |
|--|--|-------|------------------------|--------|
| | | | EPA 200.8 | Result |
| 6/21/2023 | Abingdon - Cooler by Rm 145 | Lead | EPA 200.8 | ND |
| 6/21/2023 | Abingdon - Teachers Lounge | Lead | EPA 200.8 | ND |
| 6/21/2023 | Abingdon - Cooler by Rm 178 | Lead | EPA 200.8 | ND |
| 6/22/2023 | Arlington Science Focus - Fountain by Rm 137 | Lead | EPA 200.8 | ND |
| 6/22/2023 | Arlington Science Focus - Bottle Filler by Rm 21 | Lead | EPA 200.8 | ND |
| 6/22/2023 | Arlington Science Focus - Cafeteria Fountain | Lead | EPA 200.8 | ND |
| 6/22/2023 | Barcroft - Main Kitchen Sink | Lead | EPA 200.8 | ND |
| 6/22/2023 | Barcroft - Water Fountain in Lobby | Lead | EPA 200.8 | ND |
| 6/22/2023 | Barcroft - Cooler by Rm 122 | Lead | EPA 200.8 | ND |
| 6/22/2023 | Barrett - Cooler in Cafeteria | Lead | EPA 200.8 | ND |
| 6/22/2023 | Barrett - Water Fountain by 215 | Lead | EPA 200.8 | ND |
| 6/22/2023 | Barrett - Water Fountain by 123 | Lead | EPA 200.8 | ND |
| 6/21/2023 | Claremont - Cooler by Rm 115 | Lead | EPA 200.8 | ND |
| 6/21/2023 | Claremont - Cooler by Rm 144 | Lead | EPA 200.8 | ND |
| 6/21/2023 | Claremont - Bubbler in Rm 155 | Lead | EPA 200.8 | ND |
| 6/21/2023 | Drew - Main Kitchen Sink | Lead | EPA 200.8 | ND |
| 6/21/2023 | Drew - Bubbler in Rm 160 | Lead | EPA 200.8 | ND |
| 6/21/2023 | Drew - Cooler by Elevator | Lead | EPA 200.8 | ND |
| 6/21/2023 | Gunston - Cooler by Custodial Closet | Lead | EPA 200.8 | ND |
| 6/21/2023 | Gunston - Cooler by Rm 127 | Lead | EPA 200.8 | ND |
| 6/21/2023 | Gunston - Kitchen 2 Comp. Sink | Lead | EPA 200.8 | ND |
| 6/21/2023 | Heights - Kitchen Sink | Lead | EPA 200.8 | ND |
| 6/21/2023 | Heights - Bottle Filler by Rm 307 | Lead | EPA 200.8 | ND |
| 6/21/2023 | Heights - Fountain B102 | Lead | EPA 200.8 | ND |
| 6/21/2023 | Hoffman Boston - Water Fountain by Rm 14 | Lead | EPA 200.8 | ND |
| 6/21/2023 | Hoffman Boston - Water Fountain by Rm 110 | Lead | EPA 200.8 | ND |
| 6/21/2023 | Hoffman Boston - Bottle Filler in Cafeteria | Lead | EPA 200.8 | ND |
| 6/21/2023 | Innovation - Bubbler in 219 | Lead | EPA 200.8 | ND |
| 6/21/2023 | Innovation - Bubbler in 311 | Lead | EPA 200.8 | ND |
| 6/21/2023 | Innovation - Bubbler in 129 | Lead | EPA 200.8 | ND |
| 6/21/2023 | Jamestown - Cafeteria | Lead | EPA 200.8 | ND |
| 6/21/2023 | Jamestown - Water Fountain by RM 802 | Lead | EPA 200.8 | ND |
| 6/21/2023 | Jamestown - Water Fountain by RM 408 | Lead | EPA 200.8 | ND |
| 6/22/2023 | Randolph - Main Kitchen Sink | Lead | EPA 200.8 | ND |
| 6/22/2023 | Randolph - Bottle Filler by RM B107 | Lead | EPA 200.8 | ND |
| 6/22/2023 | Randolph - Cooler by Rm A 121 | Lead | EPA 200.8 | ND |
| 6/21/2023 | Taylor - Cafeteria Bottle Filler | Lead | EPA 200.8 | ND |
| 6/21/2023 | Taylor - Water Fountain by Rm 6 | Lead | EPA 200.8 | ND |
| 6/21/2023 | Taylor - Water Fountain by Rm 266 | Lead | EPA 200.8 | ND |
| 6/22/2023 | Thos. Jefferson - Kitchen 2 Comp. Sink | Lead | EPA 200.8 | ND |
| 6/22/2023 | Thos. Jefferson - Cooler by Rm B07 | Lead | EPA 200.8 | ND |
| 6/22/2023 | Thos. Jefferson - Cooler by Rm 29 | Lead | EPA 200.8 | ND |
| 6/23/2023 | Tuckahoe - Fountain by Rm 123 | Lead | EPA 200.8 | 0.0003 |
| 6/23/2023 | Tuckahoe - Bottle Filler by Rm 118 | Lead | EPA 200.8 | ND |
| 6/23/2023 | Tuckahoe - Bottle Filler by Rm 008 | Lead | EPA 200.8 | 0.0003 |
| NB: All except 2 at None Detected (ND) and those are both miniscule traces. Actionable level is 15.00 PPB | | | | |
| Any questions on these results can be directed to Jim Meikle, Director of Maintenance APS - 703 228 6617 | | | | |