

SUMMER 2024 - RESULTS FOR TESTING OF LEAD IN WATER LEVELS AT 13 APS LOCATIONS				
(ROTATING THREE YEAR CYCLE SHOWN IN THIS 'MAINTENANCE' WEB SECTION)				
Time	Date	Location	Type	Result PPB
5:21	6/26/2024	Oakridge Water Fountain by 228	Lead	ND
5:25	6/26/2024	Oakridge Water Fountain by 285	Lead	ND
5:29	6/26/2024	Oakridge Kitchen 3 -Comp Sink	Lead	0.0006
5:47	6/26/2024	Montessori Water Fountain by 190	Lead	ND
5:51	6/26/2024	Montessori Water Fountain by 152	Lead	ND
5:56	6/26/2024	Montessori Kitchen 3 - Comp Sink	Lead	ND
6:18	6/26/2024	Alice West Fleet Kitchen 3 - Comp Sink	Lead	ND
6:21	6/26/2024	Alice West Fleet Water Fountain in Gym	Lead	ND
6:29	6/26/2024	Alice West Fleet Water Fountain by 110	Lead	ND
6:39	6/26/2024	Ashlawn Kitchen 2 - Comp Sink	Lead	ND
6:41	6/26/2024	Ashlawn Water Fountain by 214	Lead	ND
6:46	6/26/2024	Ashlawn Water Fountain in Cafeteria	Lead	0.0003
6:58	6/26/2024	ATS Kitchen 3 - Comp Sink	Lead	ND
7:00	6/26/2024	ATS Water Fountain in Cafeteria	Lead	ND
7:03	6/26/2024	ATS Water Fountain by 338	Lead	0.0003
7:18	6/26/2024	Nottingham Water Fountain by 141	Lead	ND
7:22	6/26/2024	Nottingham Water Fountain by 173	Lead	ND
7:26	6/26/2024	Nottingham Kitchen 2 - Comp Sink	Lead	ND
5:30	6/26/2024	Campbell E.S. Fountain across 142 A	Lead	ND
5:35	6/26/2024	Campbell E.S. Fountain next to Room 155	Lead	0.0004
5:38	6/26/2024	Campbell E.S. Kitchen Sink	Lead	0.0006
6:00	6/26/2024	Carlin Springs E.S. Fountain next to Gym	Lead	ND
6:06	6/26/2024	Carlin Springs E.S. Fountain next to Room 194	Lead	ND
6:10	6/26/2024	Carlin Springs E.S. Kitchen Sink	Lead	0.0003
6:36	6/26/2024	Key E.S. Fountain next to Room 132	Lead	ND
6:39	6/26/2024	Key E.S. Fountain next to Room 126	Lead	ND
6:40	6/26/2024	Key E.S. Kitchen Sink	Lead	ND
7:05	6/26/2024	Glebe E.S. Fountain next to Room C129	Lead	ND
7:08	6/26/2024	Glebe E.S. Fountain next to Room A106	Lead	ND
7:15	6/26/2024	Glebe E.S. Kitchen Sink	Lead	0.002
6:30	6/27/2024	Long Branch E.S. Fountain by Room 109	Lead	ND
6:35	6/27/2024	Long Branch E.S. Fountain across Gym	Lead	ND
6:38	6/27/2024	Long Branch E.S. Kitchen Sink	Lead	ND
7:06	6/28/2024	Swanson M.S. Fountain Cafeteria	Lead	ND
7:10	6/28/2024	Swanson M.S. Kitchen Sink	Lead	ND
7:12	6/28/2024	Swanson M.S. Fountain next to Room 136	Lead	ND
7:20	6/28/2024	Washington Liberty Fountain next to concession stand	Lead	ND
7:30	6/28/2024	Washington Liberty Fountain next to 1008	Lead	ND
7:35	6/28/2024	Washington Liberty Kitchen Sink	Lead	0.0003

NB: Vast majority at None Detected (ND) and a few with miniscule traces. Actionable level is 15.00 PPB

Any questions on these results can be directed to Jim Meikle, Director of Maintenance APS - 703 228 6617